

# Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



## Test Report

No. **11-003702-PR01**

(PB-A01-02-en-01)

**Client** SARAY Aluminium

### Basis

EN 14351-1:2006+A1:2010

**Product** Tilt and turn window

**Designation** System designation: SI 58 Sistem

**Performance-relevant product details** Material: Aluminium profiles with thermal break

**Overall dimensions (WxH)** 1,200 mm x 1,500 mm

**Special features**

### Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2003-11

EN 12211:2000-06

EN 14609:2004-06

Correspond/s to the national standard/s (e.g. DIN EN)

### Representation



### Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

### Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 21 pages.

## Results

Air permeability according to EN 12207:1999-11



**Class 4**

Watertightness according to EN 12208:1999-11



**Class 8A**

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



**Class C4 / B4**

**ift Rosenheim**

16.03.2012

Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Components

Robert Kolacny, Dipl.-Ing. (FH)  
Operating Product Officer  
Building Components



ift Rosenheim GmbH

Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Telefon: 09401 91-11  
Fax: 09401 91-11  
E-Mail: info@ift-rosenheim.de

Str. 10/11 Rosenheim  
83054 Rosenheim  
E-Mail: info@ift-rosenheim.de

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
Deutscher  
Akreditierungs  
rat  
DAP-PL-0808 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60